

CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

No.: 2024312313000605

Applicant and address

Bimed Teknik Aletler Sanayi Ve Ticaret A.S.
Deliklikaya Mah. Yüzbaşı Mehmet Hilmi Cad. No:28 İç Kapı No:1,
Arnavutköy/İstanbul, Türkiye

Manufacturer and address

Bimed Teknik Aletler Sanayi Ve Ticaret A.S.
Deliklikaya Mah. Yüzbaşı Mehmet Hilmi Cad. No:28 İç Kapı No:1,
Arnavutköy/İstanbul, Türkiye

Factory and address

Bimed Teknik Aletler Sanayi Ve Ticaret A.S.
Deliklikaya Mah. Yüzbaşı Mehmet Hilmi Cad. No:28 İç Kapı No:1,
Arnavutköy/İstanbul, Türkiye

Product, series, specification and model

Cable Glands

CRX*****, CRXC*****, CRXF*****
Ex eb IIC Gb, Ex tb IIIC Db

Standards


GB/T 3836.1-2021, GB/T 3836.3-2021, GB/T 3836.31-2021

**This product(s) complies with the requirements of CNCA-C23-01: 2024
China Compulsory Certification Implementation Rule on Explosion
Protected Electrical Product.**

Issue date: 2025-08-22 Valid to: 2029-01-23


Detailed information and status of this certificate is available by using the QR code,
visiting CNEx's website or CNCA's website: www.cnca.gov.cn.

This translated document has no legal effect and shall not be used alone.



Director:

Nanyang Explosion Protected Electrical
Apparatus Research Institute Co., Ltd.



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

No.: 202412313000605

Annex: Page 1 of 6

Product information:

1. This certificate covers the following models:

- CRX*****, CRXC*****, CRXF*****+, CRXM*****+

See the following table for detailed type designation:

CRX	*	*	*	*	*	*
	1	2	3	4	5	6

1	Model codes corresponding to mounting thread types and sizes
2	Optional code: Blank: Standard clamping range XS or S: Reduced clamping range
3	Thread pitch (*) Blank: 1.5 pitch 2: 2.0 pitch
4	Mounting thread type: N: NPT M: Metric P: PG (for Ex-e only)
5	Body material: B: Brass X: Stainless steel BN: Nickel plated brass Z: Galvanized steel
6	Sealing material : S: Silicon
(*) - For Metric threads only	


CRXC	*	*	*	*	*	*	*
	1	2	3	4	5	6	7

1	Model codes corresponding to mounting thread types and
---	--



Nanyang Explosion Protected Electrical
Apparatus Research Institute Co.,Ltd.





CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

No.: 2024312313000605

Annex: Page 2 of 6

	sizes
2	Optional code: Blank: Standard clamping range XS or S: Reduced clamping range
3	Thread pitch (*) Blank: 1.5 pitch 2: 2.0 pitch
4	Mounting thread type: N: NPT M: Metric P: PG (for Ex-e only)
5	Ferule type S: Small Blank: Standard L: Large XL: X-large
6	Body material: B: Brass X: Stainless steel BN: Nickel plated brass Z: Galvanized steel
7	Sealing material : S: Silicon
(*) - For Metric threads only	

CRXF/
CRXM

* * * * * * * * * *


1 2 3 4 5 6 7 8 9 10

1	Model codes corresponding to mounting thread types and sizes
2	Optional code: Blank: Standard clamping range XS or S: Reduced clamping range



Nanyang Explosion Protected Electrical
Apparatus Research Institute Co.,Ltd.





CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

No.: 2024312313000605

Annex: Page 3 of 6

3	Thread pitch (*) Blank: 1.5 pitch 2: 2.0 pitch
4	Mounting thread type: N: NPT M: Metric P: PG (for Ex-e only)
5	Model codes corresponding to the upper thread types and sizes
6	Optional code: Blank: Standard clamping range XS or S: Reduced clamping range
7	Thread pitch (*) Blank: 1.5 pitch 2: 2.0 pitch
8	Upper thread type: N: NPT M: Metric P: PG (for Ex-e only)
9	Body material: B: Brass X: Stainless steel BN: Nickel plated brass Z: Galvanized steel
10	Sealing material : S: Silicon
(*) - For Metric threads only	


Models sizes:

Cable gland thread size code		Thread size		Cable Dia. ranges (mm)
Metric code	NPT code	Metric	NPT	Cable sheath
0S	0S	M12	1/4"	3.0-8.0



Nanyang Explosion Protected Electrical
Apparatus Research Institute Co.,Ltd.





CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

No.: 2024312313000605

Annex: Page 4 of 6


01S	01S	M16	3/8"	3.0-8.0
01	01	M16	1/2"	5.5-12.0
1XS	1XS	M20	1/2"	9.0-16.0
1S	1S	M20	1/2"	5.5-12.0
1	1	M20	1/2"	9.0-16.0
2XS	2XS	M25	3/4"	5.5-12.0
2S	2S	M25	3/4"	9.0-16.0
2	2	M25	3/4"	12.0-20.0
3XS	3XS	M32	1"	9.0-16.0
3S	3S	M32	1"	12.0-20.0
3	3	M32	1"	16.0-26.0
4XS	4XS	M40	1 1/4"	12.0-20.0
4S	4S	M40	1 1/4"	16.0-26.0
4	4	M40	1 1/4"	20.0-33.0
5XS	5XS	M50	1 1/2"	16.0-26.0
5S	5S	M50	1 1/2"	20.0-33.0
5	5	M50	1 1/2"	29.0-41.0
6XS	6XS	M63	2"	20.0-33.0
6S	6S	M63	2"	29.0-41.0
6	-	M63	-	36.0-52.0
-	6	-	2"	36.0-52.0
7XS	7XS	M75	2 1/2"	29.0-41.0
7S	7S	M75	2 1/2"	36.0-52.0
7	-	M75	-	50.0-65.0
-	7	-	2 1/2"	50.0-65.0
80XS	80XS	M80	3"	36.0-52.0
80S	80S	M80	3"	50.0-65.0
80	80	M80	3"	61.0-78.0
8X	-	M90	-	36.0-52.0
-	9XS	-	3 1/2"	50.0-65.0
8S	-	M90	-	50.0-65.0
-	9S	-	3 1/2"	61.0-78.0
8	-	M90	-	61.0-78.0



Nanyang Explosion Protected Electrical
Apparatus Research Institute Co.,Ltd.



中国认可
产品
PRODUCT
CNAS C208-P



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

No.: 2024312313000605

Annex: Page 5 of 6

-	9	-	3 1/2"	75.0-89.0
9XS	10XS	M100	4"	50.0-65.0
-	10S	-	4"	75.0-89.0
9S	-	M100	-	61.0-78.0
9	10	M100	4"	75.0-89.0
10XS	-	M110	-	61.0-78.0
-	11XS	-	5"	75.0-89.0
10S	-	M110	-	75.0-89.0
-	11S	-	5"	88.0-104.0
10	-	M110	-	88.0-104.0
11XS	-	M115	-	61.0-78.0
11S	-	M115	-	75.0-89.0
11	-	M115	-	88.0-104.0

Ambient / service temperature range:

All the models are admitted for: -60°C~+130°C

Models made of Galvanized carbon steel: -20°C~+130°C

Degree of protection: IP66/IP68 (50m/30min.)

Ex marking: Ex eb IIC Gb, Ex tb IIIC Db

- Manufacturer should organize production in accordance with the technical documents approved by the certification body.


2. Specific conditions of use:

- The coupling of the cable glands with the enclosures shall be made as indicated by the manufacturer in the documents annexed to this certificate in order to respect the type of protection of the electrical apparatus on which cable glands are mounted.
- The cable glands shall be mounted at the electrical apparatus in such a



Nanyang Explosion Protected Electrical
Apparatus Research Institute Co.,Ltd.





CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

No.: 2024312313000605

Annex: Page 6 of 6

way that accidental rotation and loosening will be prevented.

- The cable glands CRX** series are not admitted for Ex d and/or Group I (mines) applications.
- The cable glands VOLE** series when used with braided or shielded cables and CRX** series, are only suitable for fixed installations. The cables must be effectively clamped to prevent pulling and twisting.
- The cable glands shall be installed in such a way that the temperature at the mounting point will remain within the service temperature ranges accordingly to the marking.
- The degree of protection IP 66/68 will be guaranteed for the cable glands if the holes into which cable glands are mounted are suitably sealed. To this scope the correct positioning of the gaskets (for cylindrical threads) or the application of sealant on the threads (for tapered threads), shall be done as indicated in the manufacturer instruction.
- See instruction manual for other information.

3. Certificate change information:

- 1st change on August 22, 2025: Change of the address of the Applicant, the Manufacturer and the Factory.



Nanyang Explosion Protected Electrical
Apparatus Research Institute Co.,Ltd.

