

# Certificate of Compliance

**Certificate Number:**  
UL-US-L474828-08271-03405102-0

**Report Reference:**  
E474828-20150430

**Issue Date:**  
2025-02-24

Issued to:

**BIMED TEKNIK ALETLER SAN TIC A S**  
**Deliklikaya Mah. Yuzbasi Mehmet Hilmi Cad. No:28 Ic Kapı No:1,**  
**Arnavutkoy, ISTANBUL, 34555, TR**

This certificate confirms that representative samples of:

**CYMJ - Cable Fittings for Use in Zone Classified Hazardous Locations**

**See Addendum Page for Product Designation(s).**

Have been evaluated by UL in accordance with the Standard(s) indicated on this Certificate.

**UL 2225, 4th Ed., Rev. 2016-01-29, Cables and Cable-Fittings for Use in Hazardous**

Additional Information:

See UL Product iQ® at <https://iq.ulprospector.com> for additional information.

This Certificate of Compliance indicates that representative samples of the product described in the certification report have met the requirements for UL certification. It does not provide authorization to apply the UL Mark. Only the Authorization Page that references the Follow-Up Services Procedure for ongoing surveillance provides authorization to apply the UL Mark.

Only those products bearing the UL Mark should be considered as being UL Certified and covered under UL's Follow-Up Services.

Look for the UL Certification Mark on the product.



David Piecuch  
UL Mark Certification Program Owner

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact UL Solutions Customer Service at <https://www.ul.com/contact-us>.



# CERTIFICATE OF COMPLIANCE

**Certificate number** UL-US-L474828-08271-03405102-0  
**Report reference** E474828-20150430  
**Date** 2025-02-24

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

Model	Product Description
<b>Series Vela</b> , EBS followed by 1 thru 12, followed by M or N, followed by B, BN, X or A, followed by C or S, may be followed by -WC or -WS	Cable Fittings, for use only with TC-ER-HL cable, thread sizes 1/2 to 1 in. NPT or M20 to M32
<b>Series Vela</b> , EBS followed by 1 thru 12, followed by M or N, followed by B, BN, X or A, followed by C or S, may be followed by -WC or -WS (	Cable Fittings, for use only with TC and TC-ER and TC-ER-HL cable, thread sizes 1/2 to 3 in. NPT or M20 to M90
<b>Series Vela</b> , EBS followed by numerals 1 thru 12, followed by M or N, followed by B, BN, X or A, followed by C or S, may be followed by <U+00BF>WC or -WS	Cable Fittings for use only with TC, TC-ER and TC-ER-HL cable. Thread sizes 1/2 to 3 in. NPT inclusive or M20 to M90 inclusive.
<b>Series Vela</b> , EBS followed by numerals 1 thru 4, followed by M or N, followed by B, BN, X or A, followed by C or S, may be followed by <U+00BF>WC or -WS	Cable fittings for use only with TC-ER-HL cable. Thread sizes 1/2 to 1-1/4 in. NPT inclusive or M20 to M40 inclusive.
<b>Series Octans</b> , EBU, followed by 1 thru 12, 23, 34, 45, 56, 67, 78, 80, 82 or 810, followed by M or N, followed by B, BN, X or A, followed by C or S, may be followed by -WC or -WS.	Cable Fittings, for use only with TC and TC-ER and TC-ER-HL cable, thread sizes 1/2 to 4 in. NPT or M20 to M110
<b>Series Octans</b> , EBU followed by numerals 1 thru 12, 23, 34, 45, 56, 67, 78 80, 82 or 810, followed by M or N, followed by B, BN, X or A, followed by C or S, may be followed by <U+FFFD>WC or -WS	Cable Fittings for use only with TC, TC-ER and TC-ER-HL cable. Thread sizes 1/2 to 4 in. NPT inclusive or M20 to M110 inclusive.
<b>Series Octans</b> , EBU, followed by 1 thru 4, 12, 23 or 34, followed by M or N, followed by B, BN, X or A, followed by C or S	Cable Fittings, for use only with TC-ER-HL cable, thread sizes 1/2 to 1-1/4 in. NPT or M20 to M40
<b>Series Octans</b> , EBU, followed by 1 thru 4, 12, 23 or 34, followed by M or N, followed by B, BN, X or A, followed by C or S, may be followed by -WC or -WS	Cable Fittings, for use only with TC-ER-HL cable, thread sizes 1/2 to 1 in. NPT or M20 to M32
<b>Series Octans</b> , EBU, followed by 1 thru 4, 12, 23 or 34, followed by M or N, followed by B, BN, X or A, followed by C or S, may be followed by -WC or -WS	Cable Fittings for use only with TC-ER-HL cable. Thread sizes 1/2 to 1-1/4 in. NPT inclusive or M20 to M40 inclusive.

# Certificate of Compliance

**Certificate Number:**  
UL-CA-L474828-08291-03405102-1

**Report Reference:**  
E474828-20150430

**Issue Date:**  
2025-02-24

Issued to:

**BIMED TEKNIK ALETLER SAN TIC A S**  
Deliklikaya Mah. Yuzbasi Mehmet Hilmi Cad. No:28 Ic Kapı No:1,  
Arnavutkoy, ISTANBUL, 34555, TR

This certificate confirms that representative samples of:

**CYMJ7 - Cable Fittings for Use in Zone Classified Hazardous Locations Certified for Canada**

See Addendum Page for Product Designation(s).

Have been evaluated by UL in accordance with the Standard(s) indicated on this Certificate.

**CSA C22.2 No. 60079-7 Explosive Atmospheres - Part 7: Equipment Protection by Increased Safety "e" Edition 2 Issue Date 10/2016**

Additional Information:

See UL Product iQ® at <https://iq.ulprospector.com> for additional information.

This Certificate of Compliance indicates that representative samples of the product described in the certification report have met the requirements for UL certification. It does not provide authorization to apply the UL Mark. Only the Authorization Page that references the Follow-Up Services Procedure for ongoing surveillance provides authorization to apply the UL Mark.

Only those products bearing the UL Mark should be considered as being UL Certified and covered under UL's Follow-Up Services.

Look for the UL Certification Mark on the product.



David Piecuch  
UL Mark Certification Program Owner

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact UL Solutions Customer Service at <https://www.ul.com/contact-us>.



# CERTIFICATE OF COMPLIANCE

**Certificate number** UL-CA-L474828-08291-03405102-1  
**Report reference** E474828-20150430  
**Date** 2025-02-24

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

Model	Product Description
<b>Series Vela</b> , EBS followed by 1 thru 12, followed by M or N, followed by B, BN, X or A, followed by C or S, may be followed by -WC or -WS	Cable Fittings, for use only with TC and TC-ER and TC-ER-HL cable, thread sizes 1/2 to 3 in. NPT or M20 to M90
<b>Series Vela</b> , EBS followed by 1 thru 12, followed by M or N, followed by B, BN, X or A, followed by C or S, may be followed by -WC or -WS	Cable Fittings, for use only with TC-ER-HL cable, thread sizes 1/2 to 1 in. NPT or M20 to M32
<b>Series Vela</b> , EBS followed by numerals 1 thru 12, followed by M or N, followed by B, BN, X or A, followed by C or S, may be followed by <U+00BF>WC or -WS	Cable Fittings for use only with TC, TC-ER and TC-ER-HL cable. Thread sizes 1/2 to 3 in. NPT inclusive or M20 to M90 inclusive.
<b>Series Vela</b> , EBS followed by numerals 1 thru 4, followed by M or N, followed by B, BN, X or A, followed by C or S, may be followed by <U+00BF>WC or -WS	Cable Fittings for use only with TC-ER-HL cable. Thread sizes 1/2 to 1-1/4 in. NPT inclusive or M20 to M40 inclusive.
<b>Series Octans</b> , EBU followed by numerals 1 thru 12, 23, 34, 45, 56, 67, 78 80, 82 or 810, followed by M or N, followed by B, BN, X or A, followed by C or S, may be followed by <U+FFFFD>WC or -WS	Cable Fittings for use only with TC, TC-ER and TC-ER-HL cable. Thread sizes 1/2 to 4 in. NPT inclusive or M20 to M110 inclusive.
<b>Series Octans</b> , EBU, followed by 1 thru 12, 23, 34, 45, 56, 67, 78, 80, 82 or 810, followed by M or N, followed by B, BN, X or A, followed by C or S, may be followed by -WC or -WS	Cable Fittings, for use only with TC and TC-ER and TC-ER-HL cable, thread sizes 1/2 to 4 in. NPT or M20 to M110
<b>Series Octans</b> , EBU, followed by 1 thru 4, 12, 23 or 34, followed by M or N, followed by B, BN, X or A, followed by C or S, may be followed by -WC or -WS	Cable fittings, for use only with TC-ER-HL cable, thread sizes 1/2 to 1-1/4 in. NPT or M20 to M40
<b>Series Octans</b> , EBU, followed by 1 thru 4, 12, 23 or 34, followed by M or N, followed by B, BN, X or A, followed by C or S, may be followed by -WC or -WS	Cable Fittings for use only with TC-ER-HL cable. Thread sizes 1/2 to 1-1/4 in. NPT inclusive or M20 to M40 inclusive.